CALIFORNIA ISO

California ISO Declared Emergencies For 2002

Date	Day	Forecasted Peak Demand (MW)	Actual Peak Demand (MW)	Interruptible Load (MW)**			Stage 1	Stage 2	Stage 3
				Non-Firm	Firm	CDWR			
6/18/2002	Tuesday	34,651	34,845	0	0	326			
7/9/2002	Tuesday	40,402	41,838	0	0	0	14:40-19:00		
7/10/2002	Wednesday	42,564	42,441	1320	0	204	14:30-17:59	15:00-17:59	
9/3/2002	Tuesday	38,934	40,835	792	0	110			
							2	1	0

* Actual Peak Demand includes the Interruptible Load.

** Interruptible Load is approximate and based on information provided by the UDCs.

Stage 1 Emergency Notice is declared by the ISO any time it is clear that an Operating Reserve shortfall (less than MORC minimum) is unavoidable or, when in real-time operations, the Operating Reserve is forecast to be less than minimum after utilizing available resources.

Stage 2 Emergency Notice is declared by the ISO any time it is clear that an Operating Reserve shortfall (less than 5%) is unavoidable or, when in real-time operations, the Operating Reserve is forecast to be less than 5% after dispatching all available resources.

Stage 3 Emergency Notice is declared by the ISO any time it is clear that Operating Reserve is less than the ISO's single largest resource or when, in real-time operations, the Operating Reserve is forecast to be less than the single largest resource

2003-R-YCWA-3